



NOTES:

1. IF PUTTING LANDSCAPE DRIPLINE UNDER SOIL, DO NOT BURY MORE THAN 2" BELOW GRADE AND INCLUDE AIR RELIEF VALVE (SEE DRW NO L-13 "AIR RELIEF VALVE KIT-AR VALVE KIT")

DRAWN AJD	 <b>CITY OF BEND</b>	<b>CITY OF BEND</b> STANDARD DRAWING 710 NW WALL ST., BEND, OREGON 97701  <b>DRIPLINE 2" BELOW GRADE POTABLE SYSTEM</b>	SCALE NTS
DIV LNDSCP			DATE 11/01/2024
REV DATE			APPR
			STD DWG L-16