



NOTES:

1. ALL PIPES SHALL HAVE RESTRAINED JOINTS.
2. MJ x MJ TEE OR MJxMJxSWIVEL (REQUIRES ENGINEER APPROVAL) WITH 6-INCH VALVE AT THE MAINLINE.
3. FINISH GRADE OF HYDRANT SHALL BE SET AT BURY LINE TO A MAXIMUM OF 3" BELOW BURY LINE FOR NEW INSTALLATION AND MAX OF 6" FOR RETROFITS. NO HYDRANT EXTENSIONS PERMITTED ON NEW INSTALLATIONS.
4. SET HYDRANT PLUMB. COMPACT ALL BACKFILL PER SPECIFICATIONS.
5. NON-WOVEN SEPARATION FILTER FABRIC OR PLASTIC (OSS TABLE 02320-4) INSTALLED BETWEEN UNDISTURBED EARTH AND DRAINROCK PRIOR TO BACKFILL.
6. HYDRANTS SHALL BE MANUFACTURER'S RED. NO OTHER COLOR IS PERMITTED.
7. USE 45 DEGREE OR 22.5 DEGREE BENDS TO ADJUST ACCORDINGLY TO ACHIEVE MAX DEPTH REQUIREMENT.

|       |       |  |  |         |            |
|-------|-------|--|--|---------|------------|
| DRAWN | CJH   | <br><b>CITY OF BEND</b> | <b>CITY OF BEND</b><br>STANDARD DRAWING<br>710 NW WALL ST., BEND, OREGON 97701<br><br><b>TYPICAL HYDRANT</b> | SCALE   | NTS        |
| DIV   | WATER |  |  | DATE    | 11/01/2024 |
| REV   |       |  |  | APPR    |            |
|       |       |  |  | STD DWG | W-7        |